# SYSTEM OF HOT WATER HEATING



Hashrush & Co.

PORT TATO





# Inrush System of Hot Water Heating

In this catalog are set forth the advantages of Thrush Regulated Hot Water Heating together with useful tables of valuable data for heating contractors.

HaThrush Co.

PERU



# What is the Most Satisfactory Method of Heating?

HOT water heating, in the opinion of the best modern Heating Engineers, is the most satisfactory and economical method of heating for residences, apartments, greenhouses, garages, and store rooms. Careful tests lasting over several years prove that even gravity Hot Water Heating Systems actually save 20% in yearly fuel consumption over steam. The Thrush Controlled Hot Water Heating System provides the most highly efficient and economical heating plant possible, saving 30% to 40% in fuel consumed as compared with gravity Hot Water or with Steam.

# Why Hot Water is More Satisfactory

In a steam heating plant the temperature of the steam cannot be controlled because steam must always carry at least 213 degrees temperature. Steam is either on full force or it is shut off entirely. There is no "in between" stage for moderate weather. If the steam is shut off at the radiator, coal is being wasted at the boiler because the steam is there just the same doing no useful work.

In a Hot Water Heating plant, on the other hand, the temperature of the water can be delicately controlled to provide just the right amount of room temperature for the requirements of the weather. Hot Water will heat rooms sufficiently warm in the coldest of weather and it will keep the rooms comfortable in mild weather without waste of fuel. With Hot Water you generate just as much heat as you need.

### WEATHER FOR AVERAGE HEATING SEASON In New York, Boston, Chicago, Pittsburgh and St. Louis

Oct. Nov. Dec. Jan. Feb. Mar. Apr

					0.01 2.		- Pr.
Highest tempera-							
ture degrees F.	87	68	61	55	50	71	82
Lowest tempera-							
ture degrees F.	34	24	6	12	4	6	16
Mean temperature							
month, degrees F.	58	46	34	32	28	37	50
Greatest daily			0 -	_	20	01	00
range, degrees F.	29	24	29	29	26	37	38
Least daily range	20	_ 1	20	20	20	01	90
		_	_				
degrees F.	6	5	5	5	5	7	6
This chart is con	npiled	from	U.S.	Bure	au rei	orts.	

# The Flexibility of Hot Water Easily Accommodates the Weather Changes

The undoubted advantages of hot water over steam and hot air heating are

- Mildness and consequent healthfulness.
- Elasticity of operation.
- 3. Ease of installation.
- 4. Economy in fuel consumption.

# Thrush Regulated Hot Water

When you add to these advantages of the ordinary hot water heating plant, the positive control of temperature provided by the Thrush System of Automatic Temperature Damper Regulation, you reach the highest point of efficiency in heating possible.

The Thrush System provides a closed system under pressure that promotes rapid circulation and intensifies the heat in the radiators by increasing heat transmission. The Thrush System makes any hot water heating plant vastly more efficient.


# **How Best Control Temperature?**

There are various methods of temperature regulation. The Thrush method controls temperature at the source. Not at the radiator in the room nor by the temperature of the room,—but by the temperature of the water itself, is the only basically correct method of control. Room temperature regulation not only does not accomplish its purpose but wastes fuel. By the time the room is hot enough to operate the mechanism the fire is going so strong that the mere closing of the dampers will not check it. The chances are that by the time the room cools off enough to open the dampers again the charge of fuel will be so nearly consumed that the opening of the dampers will not suffice to restore the proper room temperature.

# Features of Thrush Regulation

With the Thrush System installed the dampers are automatically closed when the *temperature of the water* reaches a point where it *will produce* the maximum temperature desired in the room. While the room may still be warm, the Thrush System opens the dampers again as soon as the *temperature of the water* has dropped to a point which would eventually reduce the temperature of the room to a point below the minimum if the dampers were not immediately opened. By this you can see that Thrush System provides the most practical heat regulation and also conserves the fuel with the utmost possible efficiency.

The Expansion (or Pressure) Tank is one of the important factors in connection with any hot water heating system. It must be capable of providing sufficient capacity for the range of temperature fluctuations which must be encountered, without wasting the hot water from the system unduly. The expansion and contraction of the water in a hot water heating system is as constant as the change of the water temperatures, which usually vary from 110 degrees to 200 degrees throughout the heating season. Thus there is an almost constant flow of water to and from this tank, which must serve as a reservoir for the surplus water when the system is hot, and to replenish the water back to the radiators when the system cools. It is the surest and most dependable means yet devised to automatically perform this work.



# The Complete Thrush System

Class "A" Equipment

Briefly, Thrush System Class "A" Equipment as shown above comprises the Thrush Automatic Damper Regulator. The Thrush Differential Pressure Relief, the Air Tight Pressure Tank, the Thrush Damper Equalizers, Thermometer and Special Gauge. It is all complete ready to install, with diagrams and charts for every type of boiler in common use.

Thrush System is a controlled hot water heating system operating under a slight pressure. The Expansion (or Pressure) Tank is placed close to the boiler in the basement, making installation easy and eliminating all danger of freezing. By reference to Figure 1 above, it will be seen how simple it it is to install the entire Thrush Equipment, while it requires on the average eight hours for a steam fitter and his helper to properly install the old system with the expansion tank in the attic. The saving in labor and material will more than neutralize the added cost of Thrush Equipment.



Fig. No. 4
Patented—Complies with Code
A. S. M. E.

# The Thrush Differential Pressure Relief

The Thrush System is a closed system operating under pressure. It has a *safe* and *positive* means of relieving excess pressure *with absolute certainty*.

The Thrush Differential Pressure Relief Valve is assembled in a way that will not permit dirt or sediment to accumulate around the seat and will therefore always close tight against the leakage of water when the pressure in the

system has been reduced to the proper working condition. The valve really seats upward against the ceiling.

It is set to open at approximately 26 pounds pressure or an equivalent of about 60 feet altitude, which is suitable pressure for 1, 2 and 3 story buildings. Special adjustments can be made at our factory to meet the requirements of higher buildings when ordered.


It cannot fail to operate when the pressure has reached the maximum for which it is set because the differential ratio between the valve disc and the diaphragm which operates it is 10 to 1. This provides a tremendous safety factor and insures positive overflow of excess water in the heating system when needed. This certain control makes it possible to maintain higher pressure with safety and thus insure better and quicker circulation. The Relief Valve is connected to the water supply line and there is no circulation of water through the device except at such times as excessive expansion takes place. It is therefore filled with the coolest water in the system which preserves the elements from deterioration.

If the system is drained during the winter on account of closing up of building for any reason, the Differential Relief Valve should be disconnected and all of the water poured out of it, then reconnected to the system.

# How It Works

The water enters the Differential Pressure Relief Valve at A, passes through opening B into By-Pass C, to opening D into top Chamber E. (See Figure 5). The Valve Member is closed tight when not under pressure by means of the tension of Coil Spring 7.

As pressure accumulates from the system, Diaphragm 9 is forced against Adjustable Plate 8, which pushes down upon Valve Stem 4.



When pressure has become sufficient to counteract the tension of Coil Spring 7, the Valve unseats and allows the water from Chamber A to pass out through Middle Chamber of opening G. As pressure recedes coil spring pulls Valve Disc against seat and overflow ceases.

Not only is the safety factor of the Thrush Differential Pressure Relief Valve ample to eliminate all possible danger, but even if the spring should break the only result would be immediate relieving of the pressure. Breakage of a spring does not put the boiler in danger of bursting but merely allows the excess pressure to escape at an even lower pressure than it would under normal working conditions. This is due to the fact that the Thrush valve seats on the ceiling, leaving no pocket where dirt can accumulate to prevent proper seating.

When installing a Thrush Differential Pressure Relief Valve always cause the system to overflow when you first fill it so that water will pass above the valve seat and submerge the valve disc. This prevents all possibility of corrosion. The ordinary type of relief valve is open to the atmosphere on one side and the action of air on the valve with the slight amount of water which may seep through encourages corrosion. The Thrush valve on the other hand is insulated from the air by water above valve seat and corrosion prevented.



### A Vital Part of Any Hot Water Heating System

### DIMENSIONS AND CA-PACITIES OF TANKS

Fig. No. 6

# Thrush Air Tight Pressure Tanks

The Thrush Pressure Tank conserves hot water. Whenever water is heated, it expands and some water is forced out of the system. In the ordinary open gravity or the "tankless" system it overflows out into the air, and is wasted. It takes coal to raise the temperature of water, and every time hot water is wasted, coal is wasted, for when the water in the system cools and contracts, fresh water from the mains must be taken in, and that calls for more heat immediately.

In Thrush System this water that is forced out of the system goes into the Thrush Pressure Tank where it is saved, and it returns to the system immediately when the water in the system has contracted again.



Every time *fresh* water is let into a boiler it deposits lime, magnesia and other insulating substances on the boiler plates. This gradually reduces the heating efficiency of the plant. By keeping the same water in the system for a long time, the Thrush Pressure Tank not only prevents waste of fuel but helps to *cut down this deposit of mineral to a minimum*.

# Why Thrush Tanks Won't Water-Log

The Thrush Pressure Tank is made of copper bearing steel. It is air tight and every one is tested under high pressure before shipment. It is never completely filled with water. More than half of it is filled with air.

The same air which gets into radiators and causes trouble in the




Fig. No. 8

ordinary system is here put to work. By the Thrush method of piping, all the air which gets into the system through the water mains or which is liberated at the hot boiler plates naturally rises to the highest point immediately above, which is the tank. The illustration above shows the path which the air takes direct from the boiler to the Pressure Tank. Thus not only is air kept from the radiators but the needed supply of air in the Pressure Tank is constantly maintained.

When installing a system requiring more than 2000 square feet of radiation, simply use more than one tank. For instance a job carrying 2750 square feet of radiation requires one No. 3 Tank and one No. 1 Tank as shown in the illustration below.

Two tanks are used because a tank larger than our No. 3 would be too large to go between joists, and a tank that is

set on the basement floor is apt to waterlog. Fig. 9 shows the proper arrangement.

When buildings are higher than three-story be sure to indicate it in ordering so that proper equipment can be supplied.




Fig. No. o



# Thrush Damper Equalizers

With the Thrush System of Hot Water Heating all pulleys are dispensed with and in their stead Thrush Damper Equalizers are

furnished. These Damper Equalizers can be delicately balanced for extremely sensitive operation and they will continue to function in this delicately sensitive manner for an indefinite period. They will not stick or bind at any time. Therefore, the full power from Thermostat lever is applied to the opening of the dampers. Practically none is lost in transmission. It requires comparatively few degrees of temperature change between the opening and the closing of the Dampers—consequently more uniform house temperatures.

The usual arrangement for the opening of Dampers consists of a chain operating on a pulley. The pulley rusts and in a short while gives evidence that the sensitiveness of the regulation is being cut down anywhere from 10% to 100%. When the chain jumps the track, there can be no regulation until the chain is put back.

There is no way for Thrush Equalizers to "jump the track" or get out of order. They'll work right at first and keep on doing it for years.



FIE No 11

Thrush Damper Equalizers are sturdy in construction. They are made of heavy gauge steel and plated to prevent rusting.

Each one is complete with a screw held in the top making it a simple matter to install. No loose screws or screw driver to bother with.

The movable head of the Thrush Regulator may be swung into line with Dampers and Damper Equalizers so that greatest leverage in Damper operation is provided.

# A Simplified Gauge on Thrush System

The original dial design of this gauge makes it very easy for the most inexperienced person to operate Thrush System at maximum efficiency. Instead of the usual altitude dial, this dial bears markings both in pres-



Fig No. 12

sure and in feet. The number of feet from boiler to highest point in the system indicates point at which boiler should be filled with water so the proper pressure will be registered. Red Arrows plainly labeled point to place where indicator should stand for one or two story building, for three story building, and for four story building.

# 260 / 0 / 20

Fig. No. 13

### Thrush Thermometer

Thrush System includes a delicately responsive thermometer which indicates the water temperature in the boiler. This enables the operator to adjust the regulator with full knowledge of conditions within the boiler, and weights can be set to provide just the proper degree of water temperature according to the table of temperatures which is on the instruction sheet furnished with Thrush System. It is also reproduced below.

# Table of Temperatures

This shows the approximate boiler temperatures which should be maintained to meet varying outdoor temperatures. They will vary of course in proportion to the condition or construction of the building.

Outside Temperature Boiler	r Temp.
60 degrees above	degrees
50 degrees above	degrees
40 degrees above	degrees
30 degrees above	degrees
20 degrees above	degrees
10 degrees above	degrees
0 Zero	degrees
10 degrees below	degrees
20 degrees below 210	degrees
30 degrees below225	degrees




Fig. No. 14

# Thrush System With Sectional Boiler

One of the advantages of Thrush System is that it can be applied to a heating plant of any kind or size. It is adapted to large as well as small installations. The above illustration shows the proper method of installing with sectional cast iron or steel boilers.

The same method of trapping the air into the expansion tank can be applied to installations on sectional boilers and in fact to installations on boilers of every kind.

The use of Thrush Damper Equalizers in place of pulleys here offers a big advantage also. As the installation above shows, Thrush Damper Equalizers may be separated and placed at any point desired to obtain maximum efficiency of operation.

With each Thrush System we pack an instruction sheet which gives complete diagrams for installation on each popular type of boiler.

### THRUSH EQUIPMENT FOR OIL BURNERS




Fig. No. 15

# Thrush System of Hot Water Heating

Class "B" Equipment

While we recommend that a complete Thrush System be installed wherever possible, there are cases in which the Regulator may not be required.

The advantages of the Thrush Closed System with the water under pressure, producing an accelerated circulation and increased heat transmission, are so well known that many installations where other forms of regulation are furnished with the boiler, are made with Class "B" Equipment added. An oil burner for instance usually has its own regulator, but the addition of Thrush Class "B" Equipment will greatly increase the heating efficiency of the job.

Class "B" Equipment consists of the Thrush Air Tight Steel Pressure Tank, Thrush Differential Pressure Relief, Thrush Thermometer and Thrush Special Gauge. It is listed separately in our price list.

# Thrush System\_of


The Thrush Air Tight Pressure Tank. It is made of copper bearing steel, thoroughly tested before shipping.

Thrush Damper Equalizers. Provide delicately sensitive balanced operation of Dampers. Much better than pulleys.

Thrush Method of Piping. Traps air from Flow risers and leads it into the tank where it serves a useful purpose. Keeps it out of the system.


Uniform temperatures maintained. Adjustment made by merely sliding weights forward or backward on lever.

Thrush Thermometer. Sets in boiler. Indicates temperature of water within boiler enabling operator to maintain desired room temperatures.



# Easy to Install-Ecol

# Hot\_Water Heating



Filling Connection.
Thrush method of installation takes only six feet of pipe and eight connections. Quick and easy.

Thrush Differential Pressure Relief. Provides positive safe overflow. Maintains additional pressure on system, relieving excess pressure instantly.

Thrush Automatic Damper Regulator. Mointains temperature of unter in radiators and thus uniform room temperature

Thrush Cauge Ho a simplified dial with marking both in pressure and and in feet. Easy to understand.

Drain Value To drain open air rent on radiators. Remove drain plug in pressure tank

eight fitting needed

OT WATER

SYSTEM

omical in Operation

# Thrush Differential Pressure Relief Valve and Air Tight Pressure Tank

For Arcolas, or similar installations where overhead piping system is used and where radiators set on same floor level as the heater, the illustration at bottom of this page shows how to apply the Thrush method of harnessing the system. We guarantee the circulation in any Arcola or similar installation where our instructions for the use of the Thrush Differential Pressure Relief Valve and Pressure Tank are adhered to.

# **Instructions**

Connect Thrush Differential Pressure Relief Valve to the return pipe, near heater, as shown, and extend it above top of heater. Locate it so that it will be at least 12" away from smoke pipe. Overflow pipe may be dropped through floor below.

Vent pipe must be located under expansion tank as shown. It should be about 14" size, with pet cock located within easy reach from first floor. Altitude pressure gauge should always be used and set to indicate about 20' altitude. When the system is filled with water at start, vent air through 14" vent pipe and fill until altitude gauge shows 20'.




Fig. No. 17





Fig. No. 18

# Thrush Domestic Water Relief Valve and Automatic Temperature Control

For controlling the water temperature in Domestic Water Heater and storage tank. The Thrush Automatic Temperature Damper Regulator is very sensitive in its operation and will maintain uniform water temperatures without attention.

# Safety



The Thrush Domestic Water Relief Valve is a Differential Pressure Relief Valve similar to the larger Thrush valve on standard Thrush Hot Water Heating Systems. It is made for operation on higher pressures however, and is the first entirely satisfactory relief valve for the purpose. The valve seats on the ceiling and cannot stick, corrode or become clogged with dirt. It is positively safe and certain in its action.

# Our Engineering Department

Thrush engineers design piping plans for the trade and for architects who are using and specifying Thrush Hot Water Heating Systems in every part of the country. This valuable service is available to the legitimate trade only.

It doesn't make any difference whether your problems have to do with the largest apartment building or the smallest bungalow, they will be handled in a most practical and efficient manner.

A well designed piping plan showing in detail the Thrush self-controlled Hot Water System, together with all of the various pipe sizes and connections and, in fact every part of the heating equipment, enables you to do your work better and quicker.

Where Thrush plans are used and faithfully followed, there is every assurance that the job will give the utmost satisfaction to the customer.

Our supervising engineers are men who have spent many years specializing in hot water heating installations. Don't wait till you have the order, to ask for plans. Let us help you get the job. The right plan may help you win the bid by reducing costs.

# When Submitting Plans

1st—Indicate location of boiler and chimney flue. State whether round or square boiler is to be used.

2nd—Show exact location and footage of radiators.

3rd—Be sure to show location of stairway in basement.


4th—Indicate clearly the size of each room.

5th—Closets should be shown.

Give as much information as possible concerning the building to be heated. It is always better for the heating contractor to figure the radiation, but if this is not done, be sure to show the exact size of each room, size and location of windows and doors, also the height of ceiling. All outside walls are figured as exposed wall unless it is indicated otherwise.

Remember that our engineers are not on the ground and must have the information submitted as completely as possible. While it is impossible for us to guarantee the radiation footages shown on plans, yet with the proper information furnished with your plans, you can depend upon our estimates in every instance. You should indicate whether building is of frame, brick or other form of construction.

### LET US MAKE YOUR PIPING PLANS FREE



# Instructions for Proper Designing

The Thrush piping system has attained the limit of simplicity and economy in both quantity and size of pipe and fittings, the installation of which is so safe and easy that the following simple instructions should enable any steam fitter to secure perfect results in every instance.

THE CHIMNEY of the building to be heated should have sufficient height and area to supply ample volume and velocity of draft for the boiler attached to it. This permits the boiler to attain its full efficiency and is an aid to fuel economy.

THE BOILER capacity rating should be estimated on a basis of at least eight hour firing periods, and on the average of 100% more rating capacity than the total square feet of direct radiation to be heated.

RADIATORS should be located on outside walls whenever possible, because that is where the cold air is entering.

RADIATORS in which the mains terminate should have one size larger valves. This serves as a distinct aid to circulation, because the radiators in which the mains terminate serve as a link to join together the flow and return mains.

NO REDUCTION should be made in flow mains consisting of  $1\frac{1}{2}$ " pipe and under unless the reduction can be made where mains turn at right angles, then use reducing ells, one size reduction only. If mains run straight to end radiator they should extend full size to the end and look up to the radiator valve with reducing ells. Return mains should be graduated in size according to valve areas.

THE PIPING SYSTEM should be laid in with the idea of extending the mains in the most direct and convenient way, so as to terminate in a first floor radiator furthest from the boiler, and utilize as much as possible short branch pipes between mains and radiators. Avoid terminating mains in risers extending to a second floor radiator.

SIZE OF MAINS to use for a given amount of radiation is ascertained by determining the size and area of valve to be used for each radiator connected to a main. The combined valve areas will be the area of main to use. The same principle applies to risers when one or more radiators are to be connected to them.

# Data for Figuring Radiation

1. Simple Method—There is a simple rule for figuring hot water radiation that gives approximate results and may be used with a reasonable degree of dependability for residence heating where the temperature required is 70 degrees.

# Simple Table

Divide square feet of opening by 2. Divide square feet of Exposed Wall by 10. Divide the cubic contents by 60.

The sum of the figures obtained by these divisions is the approximate amount of radiation required. This rule, however, does not take into account the various conditions which the heating contractor must meet and results are approximate.

2. Accurate Method—For the purpose of accurately figuring radiation under all conditions, we give you the two tables shown on pages 26 and 27. These tables give standard heat losses as compiled by recognized authorities. Radiation can be definitely computed for buildings of any construction and for any desired temperature by using the data given in these tables.

For example let us figure the radiation required to maintain 70 degrees temperature in the large living room of a well built frame residence when the weather is zero outside. The room is 14 feet wide, 28 feet long, with nine foot ceiling, medium tight windows and one door, half of which is glass.

# Residence Example No. 1

(1) Sq. ft. Windows (medium) (2) Sq. ft. door	
(3) Sq. ft. exposure(4) Cubical contents	$784 \times 23.1 = 18110.4$ $3528 \times 1.27 = 4480.5$
Total B. T. U. Loss	31259.7

For hot water radiation, divide total B. T. U. Loss 31,259.7 by 170=184 sq. ft. radiation. (See bottom of table No. 2).

As another example, say you have a Garage with 8" brick walls to be heated to 50 degrees temperature with zero outside. Size, 40 ft. x 80 ft. exposed on one side and both ends, with average ceiling 12 ft. high, composition roof, wood sheathing, with 14 single glass windows, (loose) and 1 solid wood door.

# Garage Example No. 2

		Sq. Ft. of	B. T. U.
		Exposure	Loss
		Facto	I.
(1)	Sq. ft. of windows	$=336 \times 75$	=25200
(2)	Solid wood door	$81 \times 24$	= 1944
(3)	Exposure Walls, openings deducted	$1503 \times 21$	=31563
(4)	Cement floor	$3200 \times 15$	.5 = 49600
(5)	Roof exposure	$3200 \times 22$	=70400
(6)	Cubical contents	.38400×	.9 = 34560
	Total B. T. U. Loss		213267

For hot water radiation, divided 213,267 by 170=1255 sq. ft. radiation. (See bottom of table No. 2).

By studying the above problems and studying the table also you will get a good idea of the correct method of figuring radiation for any desired temperature and for almost every type of construction by the use of these tables. For instance, factors for example No. 1 are found under the 70 degree column and factors shown by example No. 2 are found under the 50 degree column in the tables.

When measuring building to be heated, it is advisable to make a rough outline of the various rooms, showing closets, offsets, and stairways. Windows and doors should be marked on sketch. When measuring for sizes include entire opening and not glass only. Be careful to ascertain as nearly as possible how the building is constructed. You cannot exercise too much care in learning all you can about the building to be heated.

# RADIATOR VALVE SIZES For the Thrush Hot Water Heating System


Up to 125 sq. ft.	FIRST FLOOR.	1" valve
Up to 90 sq. ft.	SECOND FLOOR.	3⁄4" valve
Up to 120 sq. ft	THIRD FLOOR.	3⁄4″ valve

# PIPE SIZES and Areas Ordinarily Used for Hot Water Heating


1/2" pipe and valve area	.30 sq. in.
3/4" pipe and valve area	.50 sq. in.
1" pipe and valve area	.85 sq. in.
1¼" pipe and valve area	1.50 sq. in.
1½" pipe and valve area	2.00 sq. in.
2" pipe and valve area	3.36 sq. in.
2½" pipe and valve area	4.80 sq. in.
3" pipe and valve area	7.40 sq. in.
3½" pipe and valve area	9.80 sq. in.
4" pipe and valve area	12.70 sq. in.
$4\frac{1}{2}$ " pipe and valve area	15.90 sq. in.
5" pipe and valve area	20.00 sq. in.
6" pipe and valve area	28.80 sq. in.

PITCH MAINS about one-half inch for each ten lineal feet of pipe. Short branch pipes should have about one inch pitch to three feet of pipe. Ream the burr from all pipe ends.

### THRUSH SIMPLIFIED INSTALLATION



### PUTS PROFIT IN YOUR BANK BOOK



## **Connections Recommended**


Fig. 22 shows cross section of mains with branch connections out of side of mains to radiators. Side connections



Fig. No. 22

are recommended because the circulating water will be more uniformly distributed throughout the various radiators.

Fig. 23 shows method of connecting two radiators on one set of risers. Note the largest radiator is always supplied from the top of riser.







Fig. 24 illustrates method of connecting branches to upper floors. The largest radiator should be taken from the connections at top of risers.

Figure 25 shows the Thrush method of constructing pipe coils for hot water heating. This provides uniform distribution of water supply to each coil and completely eliminates short circuits so commonly found in pipe coils.



### GREENHOUSE HEATING

Thrush Equipment is particularly satisfactory for Greenhouse Heating Plants. It produces a mild uniform temperature without fluctuations and is entirely dependable.

In figuring radiation for a Greenhouse, the problem is one concerned almost entirely with exposed surfaces. Cubic contents is rarely, if ever taken into account. The entire area of glass should be determined, counting every 5 feet of exposed side wall of glass by the following coefficients as shown in the table to secure the different temperatures required at zero outside.

To	heat	Greenhouse	to	40	divide	No.	sq. ft.	of	glass	by	6
6.6	6.6	4.6	4.6	45	66	No.	4.6	6.6	6.6	4.6	5
6.6	6.6	4.6	6.6	50	66	No.	6.6	6.6	4.6	6.6	4
4.6	66	6.6	6.6	55	66	No.	4.6	6.6	6.6	4.4	3.75
4.6	6.6	6.6	6.6	60	4.4	No.	4.4	6.6	6.6	6.6	3.5
4.6	66	44	6.6	65	64	No.	6.6	6.6	6.6	4.4	3.25
4 5	66	6.4	4.6	70	6.6	No.	6.6	4.6	6.6	6.6	3

In localities where the temperature falls below zero, add to the result obtained by the above table, 1% for every degree below zero.

To find the square feet of radiation in pipe, use the table below. Multiply the length of the pipe by the coefficient shown in the table corresponding to the diameter of pipe being used.

34 "	1"	1 1/4 "	1 1/2 "	2"	21/2"	3"	3 1/2 "	4"	5"	6"
.275	.346	.434	.494	.622	.753	.916	1.045	1.175	1.455	1.739

In connection with designing pipe coils for greenhouse work note Fig. No. 25 on opposite page. Reducing the supply to each pipe as shown results in uniform temperatures in all pipes in coil. Area of main supply should equal combined areas of supplies to coils.



Thrush System brings satisfaction to the home owner—that makes it a good product for the man who takes pride in his work, to handle. Thrush System is neat and compact, takes very little labor to install and its popularity with both home owners and heating contractors is increasing tremendously each year.

# H. A. Thrush & Co.

Peru, Indiana

All items listed in this catalog are covered by our price list.



